

## EP008012UDSID/EP006012UDSID Timer setting

### 1. How to set up SKIM to 1 hour from the default 15 minutes.

Note: This procedures have already been done by Yasunaga as the initial setting for Enviroflo EPDS.

No.	Operating procedure	LCD Screen
1	Turn on the power ※Time 3:48 is just an example.	Auto 3:48
2	Display the clock	-
3	Press HOUR + MINUTE for 3 seconds ×2	A11
4	Program No.A11	Auto 3:48
5	Press the SET button	5 20
6	Press the MINUTE button for 3 seconds	5 0
7	Press the MINUTE button to set "0") Press 21 times ※Do not press the HOUR button	Auto 3:48
8	Press the SET button Return to automatic screen	Time "3:48"
9	Press the SET button ※Check the time	Auto 1
10	"OK" ⇒Press the SET button	"ON" 0 : 00
11	Press the SET button	"OFF" 0 : 15
12	Press the SET button	"OFF" 0 : 00
13	Press the MINUTE button Press 45 times to set 1:00 (1 hour)	"OFF" 1 : 00
14	Press the HOUR button once	2
15	Press the SET button	"ON" 0 : 00
16	Press the SET button	"OFF" 0 : 00
17	Press the SET button	Auto
18	Press the SET button	
19	Return to automatic screen	

### 2. How to confirm the timer (1 hour) setting after setup.

No.	Operating procedure	LCD Screen
1	Turn on the power	Auto 3:55
2	Display the clock	
3	Press the SKIM button to change "Auto" to "Manual"	ON Manual
4	Press HOUR + MINUTE for 3 seconds *See note on right	Auto 3:55
5	Press the SKIM button (Manual → Auto)	Time "3 : 55"
6	Press the SET button	Auto 1
7	Press the SET button	"ON" 0 : 00
8	Press the SET button	"OFF" 1 : 00
9	Press the SET button	2
10	Press the SET button	"ON" 0 : 00
11	Press the SET button	"OFF" 0 : 00
12	Press the SET button	Auto 3:55
13	Press the SET button	

<Note>

3. Skippig No.3 procedure will reset the timer setting to default (0:15).

4. Please note that there will be no change to the LCD screen after pressing HOUR + MINUTES for 3 seconds.